



LEAHI HOSPITAL
HAWAII HEALTH SYSTEMS CORPORATION

3675 Kilauea Avenue ■ Honolulu, Hawaii 96816 ■ Telephone: (808) 733-8000

April 15, 2020

TO: Interested Bidders

FROM: Scott Kawai
Contracts Department

SUBJECT: Addendum No. 1
IFB No. 20L-0040 Leahi Hospital – Suspended Walkway Repairs

Addendum No. 1 provides changes to the subject solicitation.

1. Question: What painting materials are specified and intended to be bid on for Section 09900 Painting? In Section 09900 Part 1 – General, 1.01 Summary, letter B Related Work Described Elsewhere numbers 1, 2, and 3. This listed sections 05120 Structural Steel, section 07100 Waterproofing and section 09220 Metal Lath and Portland Cement Plaster as section with Related Work that is related to section 09900 Painting. We are unable to determine what work in sections 05120 Structural Steel, 07100 Waterproofing, and 09220 Metal Lath and Portland Cement Plaster are related to section 09900 Painting.

Response: For this repair work, only bare areas affected by the repairs will be painted. These areas would be the metal lath and cement plaster railing and corrosion repairs at the deck soffit as shown on the drawings and specified in the painting section on Sheet W-1 and in the project specifications.

End of Addendum No. 1