



LEAHI HOSPITAL
HAWAII HEALTH SYSTEMS CORPORATION

3675 Kilauea Avenue ■ Honolulu, Hawaii 96816 ■ Telephone: (808) 733-8000

May 18, 2022

TO: Interested Bidders

FROM: Scott Kawai *Scott Kawai*
Contracts Department

May 18

SUBJECT: Addendum No. 1
IFB No. 22L-0505 Leahi Hospital Door Replacement

Addendum No. 1 provides clarifications for the subject solicitation.

1. Delete existing Scope of Work for Leahi Hospital, Replace Doors in Young Building and replace with the attached Revised Scope of work for Leahi Hospital, Replace Doors in Young Building.
2. Delete existing Door schedule and hardware listing and replace with attached Leahi Young Fire Doors and Hardware Schedule for HW 1 through HW 18.
3. Question: The door bottom gap measured at 1/16" – 1/8" might not be enough clearance for the door to fully open if the flooring is uneven. Please advise.

Response: In the event the floor is uneven and affects the opening and closing of the door, we will address the corrective measure after consulting with the fire inspector as the gap measurement criteria is a code requirement.

4. Question: Scope of Work #6 states all patient room doors are type D1 and shall include kick plates and view windows, however, there was view windows for existing double doors. Please clarify if kick plates and view windows is required for all doors including double doors.

Response: All existing doors that have kick plates and view windows shall be replaced with kick plates and view windows. Please refer to attachment.

5. Question: Is there a door specification available? If not, what species and finish is required?

Response: The door specification is listed in the attachment.

6. Question: Are vision panels required in the doors? If yes, what size and type of glazing?

Response: All existing doors with vision panels will be replaced with matching vision panels. Glazing shall be 1/4" wire glass.

7. Question: Do we need to replace the door frames? If yes, what type of door frame HM or Wood frames? What are the existing wall made of and thickness of the walls?

Response: The door frames do not need to be replaced.

8. Question: Requesting door hardware with equivalent manufacturers as follows:
hinges: MCKINNEY in lieu of HAGER
closer: SARGENT in lieu of LCN
lockset: SARGENT in lieu of SCHLAGE
panic hardware: SARGENT in lieu of VON DUPRIN
kickplate: ROCKWOOD in lieu of TRIMCO

Response: The listed hardware manufacturers are acceptable, contractor to verify and ensure compatibility and equivalency of hardware.

**LEAHI HOSPITAL
REPLACE DOORS IN YOUNG BUILDING
REVISED SCOPE OF WORK**

1. THERE ARE A TOTAL OF 163 DOORS TO BE REPLACED.
2. ALL DOORS SHALL BE REMOVED AND DISPOSED OF UNDER THIS CONTRACT.
3. 20 MINUTE FIRE RATED DOORS
1-3/4" THICK WOOD OR COMPOSITE DOORS AS SHOWN ON THE DOOR SCHEDULE. THE FINISH SHALL BE PLAM WOOD GRAIN FINISH. ALL DOOR SHALL BE LABELED WITH APPROPRIATE FIRE RATING.
4. 90 MINUTE FIRE RATED DOORS
1-3/4" THICK WOOD OR COMPOSITE DOORS AS SHOWN ON THE DOOR SCHEDULE. THE FINISH SHALL BE PLAM WOOD GRAIN FINISH. ALL DOOR SHALL BE LABELED WITH APPROPRIATE FIRE RATING.
5. ALL INSTALLED COMPOSITE OR WOOD DOORS SHALL NOT EXCEED TOP, BOTTOM AND SIDE GAPS BY 1/16" TO 1/8". DOORS WITH GAPS LARGER THAN ALLOWED SHALL BE REJECTED AND REINSTALLED AT CONTRACTOR'S EXPENSE.
6. CONTRACTOR IS RESPONSIBLE FOR VERIFYING DIMENSIONS OF DOOR OPENINGS TO ASSURE DOORS BEING INSTALLED WILL MEET THE ALLOWABLE GAP DIMENSIONS.
7. THE HARDWARE LIST FOR EACH TYPE OF DOOR IS SPECIFIED IN THE ATTACMENT.
8. THE CONSTRUCTION TIME SHALL BE 360 DAYS FROM THE NOTICE TO PROCEED.

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	LOCKSET	CLOSER	STOP
GRP								TA2314 4.5 X 4.5 32D	60-10G05 LL 26D	351 UO EN	406/441H
1	1ST FLR QUALITY ASSURANCE	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	1ST FLR ADH SHOWER ROOM	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	1ST FLR REHAB STORAGE	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	1ST FLR PHYSICAL THERAPY OFFICE	36	COMPOSITE	20 MIN	5" x 18"	LEVER		3EA	1EA	1EA	1EA
1	1ST FLR ACTIVITIES DIRECTOR'S OFFICE	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	1ST FLR VOLUNTEER SERVICES	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	1ST FLR RECREATIONAL THERAPY	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	1ST FLR PREP ROOM	36	COMPOSITE	20 MIN	5" x 18"	LEVER		3EA	1EA	1EA	1EA
1	1ST FLR ACTIVITY ROOM	36	COMPOSITE	20 MIN	5" x 32"	LEVER		3EA	1EA	1EA	1EA
1	1ST FLR ACTIVITY ROOM 2ND DOOR	36	COMPOSITE	20 MIN	5" x 32"	LEVER		3EA	1EA	1EA	1EA
1	1ST FLR PT BATHROOM	36	COMPOSITE	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	2ND FLR T2 NURSES MEETING ROOM	36	WOOD	20 MIN	5" x 18"	LEVER		3EA	1EA	1EA	1EA
1	2ND FLR T2 JANITORS CLOSET	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	2ND FLR INFECTION PREVENTION	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	2ND FLR T1 JANITORS CLOSET	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	2ND FLR HEAD NURSES OFFICE	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	3RD FLR HEAD NURSES OFFICE	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	3RD FLR HEAD NURSES OFFICE INSIDE	36	WOOD	20 MIN	24" X 36"	LEVER		3EA	1EA	1EA	1EA
1	3RD FLR DINING ROOM DOOR 2	36	WOOD	20 MIN	5" X 18"	LEVER		3EA	1EA	1EA	1EA
1	3RD FLR JANITORS CLOSET	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	4TH FLR STAFF BREAK ROOM	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	4TH FLR JANITORS CLOSET	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	4TH FLR HEAD NURSES OFFICE	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	4TH FLR HEAD NURSES OFFICE INSIDE	36	WOOD	20 MIN	24" X 36"	LEVER		3EA	1EA	1EA	1EA
1	5TH FLR HEAD NURSES OFFICE	36	WOOD	20 MIN	24" X 36"	LEVER		3EA	1EA	1EA	1EA
1	5TH FLR BREAKROOM SIDE DOOR	32	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	5TH FLR JANITORS CLOSET	36	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA
1	5TH FLR T1 STORAGE ROOM 6b	21	WOOD	20 MIN		LEVER		3EA	1EA	1EA	1EA

HW GROUP 1

3EA	TA2314 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	60-10G05 LL 26D	SARGENT	LOCK
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	LOCKSET	CLOSER	STOP	KICK PLATE
GRP								1A2314 4.5 X 4.5 32D	60-10G05 LL 26D	351 UO EN	406/441H	K1050 10X34 630
2	2ND FLR THELMA PARKER ROOM	36	WOOD	20 MIN	5" X 18"	LEVER	YES	3EA	1EA	1EA	1EA	1EA
2	1ST FLR OCCUPATIONAL THERAPY	36	COMPOSITE	20 MIN		LEVER	YES	3EA	1EA	1EA	1EA	1EA

HW GROUP 2

3EA	TA2314 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	60-10G05 LL 26D	SARGENT	LOCK
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP
1EA	K1050 10X34 32D	ROCKWOOD	KICK PLT

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	HINGES	LOCKSET	CLOSER	STOP
GRP							1A4A3386 4.5 X 4.5	60-10G05 LL 26D	351 UO EN	406/441H
3	3RD FLR DINING ROOM	44	WOOD	20 MIN	5" X 18"	LEVER	3EA	1EA	1EA	1EA
3	3RD FLR T1 DAY ROOM	48	WOOD	20 MIN	36" X 36"	LEVER	3EA	1EA	1EA	1EA
3	4TH FLR DINING ROOM DOOR 1	44	WOOD	20 MIN	5" X 18"	LEVER	3EA	1EA	1EA	1EA
3	4TH FLR DINING ROOM DOOR 2	44	WOOD	20 MIN	5" X 18"	LEVER	3EA	1EA	1EA	1EA
3	4TH FLR MAIN ENTRANCE	48	WOOD	20 MIN		LEVER	3EA	1EA	1EA	1EA
3	4TH FLR T1 DAY ROOM	48	WOOD	20 MIN	36" X 36"	LEVER	3EA	1EA	1EA	1EA
3	5TH FLR DINING ROOM 1	44	WOOD	20 MIN	5" X 18"	LEVER	3EA	1EA	1EA	1EA
3	5TH FLR DINING ROOM 2	44	WOOD	20 MIN	5" X 18"	LEVER	3EA	1EA	1EA	1EA

HW GROUP 3

3EA	T4A3386 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	60-10G05 LL 26D	SARGENT	LOCK
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	LOCKSET	CLOSER	STOP	KICK PLATE
GRP								T4A3386 4.5 X 4.5 32D	60-10G05 LL 26D	351 UO EN	406/441H	K1050 10X46
4	2ND FLR SOLARIUM DOOR	48	WOOD	20 MIN	36" X 36"	LEVER	YES	3EA	1EA	1EA	1EA	1EA
4	1ST FLR ADH BREAK ROOM	48	WOOD	20 MIN		LEVER	YES	3EA	1EA	1EA	1EA	1EA

HW GROUP 4

3EA	T4A3386 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	60-10G05 LL 26D	SARGENT	LOCK
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP
1EA	K1050 10 X 46 32D	ROCKWOOD	KICK PLT

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	HINGES	LOCKSET	AUTO FLUSH BLT	CLOSER	STOP
GRP							TA2314 4.5 X 4.5 32D	60-10G05 LL 26D	2942	351 UO EN	406/441H
5	3RD FLR STORAGE 3b	21 X 2	WOOD	20 MIN		LEVER	6EA	1EA	1SET	2EA	2EA

HW GROUP 5

6EA	TA2314 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	60-10G05 LL 26D	SARGENT	LOCK
1SET	2942 26D	ROCKWOOD	AUTO FLUSH BLT
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	HINGES	Combo Lock	CLOSER	STOP
GRP							T4A3386 4.5 X 4.5 32D	5021R-26D-41	351 UO EN	406/441H
6	3RD FLR MAIN ENTRANCE	48	WOOD	20 MIN		COMBO LOCK	3EA	1EA	1EA	1EA
6	5TH FLR MAIN ENTRANCE	48	WOOD	20 MIN		COMBO LOCK	3EA	1EA	1EA	1EA

HW GROUP 6

3EA	T4A3386 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	5021R-26D-41	KABA SIMPLEX	COMBO LOCK
1EA	6300	SARGENT	IC CORE
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	HINGES	EXIT DEVICE	CLOSER	STOP
GRP							T4A3386 4.5 X 4.5 32D	12-60-8813 ETL 32D	351 UO EN	406/441H
7	2ND FLR ENTRANCE	48	WOOD	20 MIN	33" X 36"	PANIC	3EA	1EA	1EA	1EA
7	2ND FLR T2 EXIT	48	WOOD	1-1/2 HR	5" X 18"	PANIC	3EA	1EA	1EA	1EA
7	2ND FLR T1 FIRE EXIT	44	COMPOSITE	1-1/2 HR		PANIC	3EA	1EA	1EA	1EA
7	3RD FLR T2 EXIT	48	WOOD	1-1/2 HR	5" X 18"	PANIC	3EA	1EA	1EA	1EA
7	3RD FLR T1 STAIRWELL EXIT	44	COMPOSITE	1-1/2 HR		PANIC	3EA	1EA	1EA	1EA
7	4TH FLR T2 EXIT	48	WOOD	1-1/2 HR	5" X 18"	PANIC	3EA	1EA	1EA	1EA
7	5TH FLR T1 EXIT	48	WOOD	1-1/2 HR	5" X 18"	PANIC	3EA	1EA	1EA	1EA
7	5TH FLR T1 STAIRWELL	44	COMPOSITE	1-1/2 HR		PANIC	3EA	1EA	1EA	1EA
7	1ST FLR ADH EWA FIRE EXIT	44	WOOD	1-1/2 HR		PANIC	3EA	1EA	1EA	1EA

HW GROUP 7

3EA	T4A3386 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	12-60-8813 ETL 32D	SARGENT	EXIT
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	HINGES	EXIT DEVICE	EXIT DEVCIE	CLOSER	STOP
GRP							TA2314 4.5 X 4.5 32D	12-60-8713 ETL 32D	12-8710 ETL	351 UO EN	406/441H
8	2ND FLR T1 DOUBLE DOOR	36 X 2	WOOD	20 MIN		PANIC	6EA	1EA	1EA	2EA	2EA
8	3RD FLR T1 DOUBLE DOORS	36x 2	WOOD	20 MIN	24" X 36"	PANIC	6EA	1EA	1EA	2EA	2EA
8	4TH FLR T1 CORRIDOR DOORS	36x 2	WOOD	20 MIN	24" X 36"	PANIC	6EA	1EA	1EA	2EA	2EA
8	5TH FLRT1 DOUBLE DOORS	36x 2	WOOD	20 MIN	24" X 36"	PANIC	6EA	1EA	1EA	2EA	2EA

HW GROUP 8

6EA	TA2314 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	12-60-8713 ETL 32D	SARGENT	V/R EXIT
1EA	12-8710 ETL 32D	SARGENT	V/R EXIT
2EA	351 UO EN	SARGENT	CLOSER
2EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	EXIT DEVICE	EXIT DEVCIE	CLOSER	STOP	KICK PLATE
GRP								TA2314 4.5 X 4.5 32D	12-60-8713 ETL 32D	12-8710 ETL	351 UO EN	406/441H	K1050 10X35 630
9	1ST FLR PT DOUBLE EXIT	36 x 2	COMPOSITE	20 MIN	22" x 33"	PANIC	YES	6EA	1EA	1EA	2EA	2EA	2EA

HW GROUP 9
6EA TA2314 4.5 X 4.5 32D MCKINNEY HINGE
1EA 12-60-8713 ETL 32D SARGENT V/R EXIT
1EA 12-8710 ETL 32D SARGENT V/R EXIT
2EA 351 UO EN SARGENT CLOSER
2EA 406 / 441H 26D ROCKWOOD STOP
2EA K1050 10X35 32D ROCKWOOD KICK PLT

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	EXIT DEVICE	EXIT DEVCIE	CLOSER	STOP	KICK PLATE
GRP								T4A3386 4.5 X 4.5 32D	12-60-8713 ETL 32D	12-8710 ETL	351 UO EN	406/441H	K1050 10X42
10	1ST FLR ADH DOUBLE DOOR	44x 2	COMPOSITE	20 MIN	6" X 32"	PANIC	YES	6EA	1EA	1EA	2EA	2EA	2EA

HW GROUP 10
6EA T4A3386 4.5 X 4.5 32D MCKINNEY HINGE
1EA 12-60-8713 ETL 32D SARGENT V/R EXIT
1EA 12-8710 ETL 32D SARGENT V/R EXIT
2EA 351 UO EN SARGENT CLOSER
2EA 406 / 441H 26D ROCKWOOD STOP
2EA K1050 10X42 32D ROCKWOOD KICK PLT

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	HOSPITAL PUSH/PULL	CLOSER	STOP
GRP								TA2314 4.5 X 4.5 32D	7824PT 26D	351 UO EN	406/441H
11	1ST FLR ADH BATHROOM	36	WOOD	20 MIN		PUSH/PULL		3EA	1EA	1EA	1EA
11	1ST FLR ADH BATHROOM 2	36	WOOD	20 MIN		PUSH/PULL		3EA	1EA	1EA	1EA
11	2ND FLR NURSES STATION 3	32	WOOD	20 MIN		PUSH/PULL		3EA	1EA	1EA	1EA

HW GROUP 11
3EA TA2314 4.5 X 4.5 32D MCKINNEY HINGE
1EA 7824PT 26D SARGENT PUSH/PULL
1EA 351 UO EN SARGENT CLOSER
1EA 406 / 441H 26D ROCKWOOD STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	HINGES	HOSPITAL PUSH/PULL	CLOSER	STOP
GRP							T4A3386 4.5 X 4.5 32D	7824PT 26D	351 UO EN	406/441H
12	1ST FLR ADH NAP ROOM	48	WOOD	20 MIN	5" x 18"	PUSH/PULL	3EA	1EA	1EA	1EA
12	3RD FLR T1 TUB ROOM	48	WOOD	20 MIN		PUSH/PULL	3EA	1EA	1EA	1EA
12	5TH FLR T1 DAYROOM	48	WOOD	20 MIN	36" X36"	PUSH/PULL	3EA	1EA	1EA	1EA

HW GROUP 12
 3EA T4A3386 4.5 X 4.5 32D MCKINNEY HINGE
 1EA 7824PT 26D SARGENT PUSH/PULL
 1EA 351 UO EN SARGENT CLOSER
 1EA 406 / 441H 26D ROCKWOOD STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	HOSPITAL PUSH/PULL	CLOSER	STOP	KICK PLATE	KICK PLATE
GRP								TA2314 4.5 X 4.5 32D	7824PT 26D	351 UO EN	406/441H	K1050 10X34 630	K1050 10X46
13	3RD FLR NURSES STATION	36	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1ea	
13	4TH FLR NURSES STATION	36	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA		1ea
13	5TH FLR NURSES STATION	36	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1ea	

HW GROUP 13
 3EA TA2314 4.5 X 4.5 32D MCKINNEY HINGE
 1EA 7824PT 26D SARGENT PUSH/PULL
 1EA 351 UO EN SARGENT CLOSER
 1EA 406 / 441H 26D ROCKWOOD STOP
 1EA K1050 10X34 32D ROCKWOOD KICK PLT

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	HOSPITAL PUSH/PULL	MAGNETIC HOLDER	CLOSER	STOP	KICK PLATE
GRP								T4A3386 4.5 X 4.5 32D	7824PT 26D	DH24120FC	351 UO EN	406/441H	K1050 10X46
14.2	2ND FLR T2 DINING ROOM	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR T2 TUB ROOM	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR T1 TUB ROOM	48	WOOD	20 MIN		PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	3RD FLR T2 TUB ROOM	42	WOOD	20 MIN		PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	
14	3RD FLR TREATMENT ROOM	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR T2 TUB ROOM	48	WOOD	20 MIN		PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR T1 TUB ROOM	48	WOOD	20 MIN		PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR T1 TREATMENT ROOM	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR T2 TUB ROOM	42	WOOD	20 MIN		PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR T1 TREATMENT ROOM	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea

HW GROUP 14.2
 3EA T4A3386 4.5 X 4.5 32D MCKINNEY HINGE
 1EA 7824PT 26D SARGENT PUSH/PULL
 1EA 351 UO EN SARGENT CLOSER
 1EA 406 / 441H 26D ROCKWOOD STOP
 1EA K1050 10X46 32D ROCKWOOD KICK PLT

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	HOSPITAL PUSH/PULL	MAGNETIC HOLDER	CLOSER	STOP	KICK PLATE
GRP								T4A3386 4.5 X 4.5 32D	7824PT 26D	DH24120FC	351 UO EN	406/441H	K1050 10X46
14	2ND FLR ROOM 210	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 211	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 214	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 212	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 200	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 203	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 204	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 205	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 201	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 206	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 207	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 202	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	2ND FLR ROOM 208	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1EA
14	3RD FLR ROOM 306	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 307	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 308	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 309	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	
14	3RD FLR ROOM 310	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 311	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 301	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 302	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 300A	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 303	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 304	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	3RD FLR ROOM 305	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 409	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 410	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 411	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 401	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 402	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 403	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 404	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 405	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 406	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 407	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	4TH FLR ROOM 408	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 508	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 509	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 511	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 510	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 501	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 502	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 500	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 503	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 504	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 505	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 506	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea
14	5TH FLR ROOM 507	48	WOOD	20 MIN	5" X 18"	PUSH/PULL	YES	3EA	1EA	1EA	1EA	1EA	1ea

HW GROUP 14
3EA T4A3386 4.5 X 4.5 32D MCKINNEY HINGE
1EA 7824PT 26D SARGENT PUSH/PULL
1EA 351 UO EN SARGENT CLOSER
1EA 406 / 441H 26D ROCKWOOD STOP
1EA K1050 10X46 32D ROCKWOOD KICK PLT
1EA DH24120FC HONEYWELL MAGNETIC HOLDER

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	CLOSER	STOP	KICK PLATE
GRP								1A2314 4.5 X 4.5 32D	351 UO EN	406/441H	K1050 10X34 630
15	2ND FLR NURSES STATION 2	36	WOOD	20 MIN	5" X 18"	REUSE COMBO		3EA	1EA	1EA	
15	2ND FLR NURSES STATION 1	36	WOOD	20 MIN	5" X 18"	REUSE COMBO		3EA	1EA	1EA	
15	2ND FLR T2 ELECTRICAL ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	2ND FLR T2 SOILED LINENS	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	2ND FLR T2 STORAGE ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	2ND FLR T1 STORAGE ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
16	2ND FLR T1 CLEAN LINEN	36	WOOD	20 MIN		REUSE COMBO	YES	3EA	1EA	1EA	1EA
16	2ND FLR T1 SOILED LINEN	36	WOOD	20 MIN		REUSE COMBO	YES	3EA	1EA	1EA	1EA
15	3RD FLR MEETING ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	3RD FLR BREAK ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	3RD FLR STORAGE ROOM 5	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	3RD FLR STORAGE ROOM 2	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	3RD FLR STORAGE ROOM 1	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	3RD FLR CLEAN LINEN	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	3RD FLR SOILED UTILITY ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	4TH FLR HEAD NURSES MEETING ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	4TH FLR T2 STORAGE ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	4TH FLR T1 ACTIVITIES STORAGE	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	4TH FLR T1 STORAGE ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	4TH FLR CLEAN LINEN ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	4TH FLR T1 SOILED LINEN	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR HEAD NURSE MEETING ROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR STAFF BREAKROOM	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR STORAGE ROOM 7	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR T1 STORAGE ROOM 6	21	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR T1 STORAGE ROOM 5	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR T1 STORAGE ROOM 4	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR T1 CLEAN LINEN	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	
15	5TH FLR T1 SOILED LINEN UTILITY	36	WOOD	20 MIN		REUSE COMBO		3EA	1EA	1EA	

HW GROUP 15

3EA	TA2314 4.5 X 4.5 32D	MCKINNEY	HINGE
1EA	REUSE EXISTING COMBO LOCK	EXISTING	COMBO LOCK
1EA	351 UO EN	SARGENT	CLOSER
1EA	406 / 441H 26D	ROCKWOOD	STOP

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	CLOSER	STOP	KICK PLATE
GRP								1A2314 4.5 X 4.5 32D	351 UO EN	406/441H	K1050 10X34 630
16	2ND FLR T1 CLEAN LINEN	36	WOOD	20 MIN		REUSE COMBO	YES	3EA	1EA	1EA	1EA
16	2ND FLR T1 SOILED LINEN	36	WOOD	20 MIN		REUSE COMBO	YES	3EA	1EA	1EA	1EA
HW GROUP 16											
3EA	T4A3386 4.5 X 4.5 32D		MCKINNEY					HINGE			
1EA	REUSE EXISTING COMBO LOCK		EXISTING					COMBO LOCK			
1EA	351 UO EN		SARGENT					CLOSER			
1EA	406 / 441H 26D		ROCKWOOD					STOP			
1EA	K1050 10X34 32D		ROCKWOOD					KICK PLT			

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	CLOSER	STOP	KICK PLATE
GRP								1A2314 4.5 X 4.5 32D	351 UO EN	406/441H	K1050 10X46
17	2ND FLR T2 TREATMENT ROOM	48	WOOD	20 MIN		REUSE COMBO	YES	3EA	1EA	1EA	1EA
HW GROUP 17											
3EA	T4A3386 4.5 X 4.5 32D		MCKINNEY					HINGE			
1EA	REUSE EXISTING COMBO LOCK		EXISTING					COMBO LOCK			
1EA	351 UO EN		SARGENT					CLOSER			
1EA	406 / 441H 26D		ROCKWOOD					STOP			
1EA	K1050 10X46 32D		ROCKWOOD					KICK PLT			

HW	LOCATION	DOOR WIDTH	DOOR TYPE	FIRE RATED	VIEW PANEL SIZE	DOOR HANDLE	KICK PLATE	HINGES	AUTO FLUSH BLT	CLOSER	STOP
GRP								1A2314 4.5 X 4.5 32D	2942	351 UO EN	406/441H
18	3RD FLR STORAGE 3a	21 X 2	WOOD	20 MIN		REUSE COMBO		6EA	1SET	2EA	2EA
HW GROUP 18											
6EA	T4A3386 4.5 X 4.5 32D		MCKINNEY					HINGE			
1EA	REUSE EXISTING COMBO LOCK		EXISTING					COMBO LOCK			
1SET	2942 26D		ROCKWOOD					AUTO FLUSH BLT			
2EA	351 UO EN		SARGENT					CLOSER			
2EA	406 / 441H 26D		ROCKWOOD					STOP			