



LEAHI HOSPITAL
HAWAII HEALTH SYSTEMS CORPORATION

3675 Kilauea Avenue ■ Honolulu, Hawaii 96816 ■ Telephone: (808) 733-8000

May 20, 2024

TO: Interested Bidders

FROM: Scott Kawai
Contracts Department

SUBJECT: Addendum No. 3
IFB No. 23L-0433 Leahi Hospital Replace First Floor Windows in Young Building

The items listed hereinafter are hereby made a part of the contract for the above project and shall the work, taking precedence over previously issued Plans and Specifications governing the items mentioned:

- 1.1 IFB TIMETABLE AS FOLLOWS
 - o Closing Date for Receipt of Bids is **May 30, 2024, at 2:00 p.m. Hawaii Standard Time.**
 - o All bids must be received by HHSC by 2:00 p.m.

- Please see attached for response to RFI dated Thursday, May 9, 2024.

END OF ADDENDUM NO. 3

Request for Information

Date: 5/20/2024
Project: Leahi Hospital – Replace First Floor Windows in Young Building
IFB No.: 23L-0433
RFI Due: Thursday May 9, 2024

1. We are requesting to substitute the EFCO 2700 windows with Arcadia IPT200. See attached substitution request. **Meeting all requirements of the specified product, we take no exceptions.**
2. Section 08520 – Aluminum Windows, does not mention anything about meeting “impact rating” or IECC requirements. General Notes on sheet T-1.0, par 4 notes “conform to 2018 IBC”. Please verify that the windows are to be impact rated per 2018 IBC. **Windows shall conform to the 2018 IBC and meet impact ratings.**
3. Per the Interim General Conditions Article 5 section 5.8.2 Superintendent. Contractor shall have competent superintendent or agent on work site while work is being performed under contract. Section 5.8.2.3 mentions: The requirements of this subsection 5.8.2 may be waived by the Engineer. Will this requirement be waived by the Engineer. **The Contractor shall have a responsible person on site at all times to oversee operations and be the intermediary with the Contracting Officer.**
4. At the site visit, it was mentioned that the hospital staff would construct barricades as needed. Please verify if the hospital will construct the barricades or will the Contractor be responsible for providing and erecting the barricades. **Hospital staff will provide barricades for the work area. All such barricades shall be scheduled and coordinated with the Contracting Officer.**
5. Will infection control barriers and other measures be required similar to the guidelines in DHA ICRA 2.0? **Barricades will be provided by the hospital staff and will address infection control.**